



## AVIZ AMPLASAMENT

AVIZ 1159/04.10.2017

**C.N.C.F."CFR"-S.A.-MUNICIPIUL BUCURESTI BULEVARDUL DINICU**

**GOLESCU NR.38 SECTOR 1**

**Destinatie –ELECTRIFICAREA SI REABILITAREA LINIEI DE CALE FERATA CLUJ-ORADEA-EPISCOPIA BIHOR-LOCALITATEA HUEDIN**

Se avizeaza favorabil lucrarea cu respectarea urmatoarelor clauze:

1. La atacarea lucrarilor se vor efectua sondaje pentru identificarea retelelor de apa-canal si se va solicita asistenta tehnica sectiei apa-canal.
2. Lucrarile de sapatura din zona conductelor de apa-canal se vor executa manual in vederea evitarii deteriorarii acestora.
3. Distantele dintre retelele de apa-canal si celelalte retele de constructii vor fi cele prevazute de normativele in vigoare.
4. De eventualele avarii aduse retelelor de apa-canal in timpul executarii lucrarilor raspunde direct constructorul.
5. **Se vor ridica la cota terenului amenajat, capacele caminelor de vizitare apa-canal, recipientii de scurgere a apelor meteorice , cutiile hidrantilor de incendiu existente si a vanelor ingropate.**
6. **La inceperea lucrarilor se va solicita de la sectia apa-canal un reprezentant care sa traseze retelele de apa si canalizare existente**

Prezentul aviz este valabil pana la data de:4.10.2018



Compartiment tehnic-avizare

Matis Adrian

**F-FP.H-07-02, ed.02/rev.0**