

Legenda/Legend

- Separator monopolar de exterior actionat manual cu CLP 25kV-1250A
  Outdoor single-phase disconnector, manual-operated with grounding-contact
- Siguranta fuzibila
  Fuse
- Descarcator cu ZnO 36kV- 10kA
  ZnO surge arrester
- Transformator monofazat de putere
  Single - phase power transformer
- Interstitiu de scanteiere
  Sparkinng gap
- Tablou electric
  Electrical panel
- Priza de pamant
  Earthing plate

ENTITATE CONTRACTANTA
CONTRACTING ENTITY

C.N.C.F. "C.F.R." - S.A.

CONTRACTANT
CONTRACTOR

Asocierea S.C. ISPCF S.A. - S.C. BAICONS IMPEX SRL

	Nume *Name*	Data *Date*	Semnatura *Signature*
Şef Proiect *Project Manager*	Gorgonetu Viorel	11.2024	
Verificat *Checked*	Spack Cristina	11.2024	
Proiectat *Designed*	Spack Cristina	11.2024	

”Modernizarea liniilor și instalațiilor din Complexul Feroviar București”
Studiu de fezabilitate

”Modernization lines and installations in the Bucharest Railway Complex
Feasibility Study

Proiect / *Project*
38 / 2022

Faza / *Phase*
S.F.
F.S.

Denumire / Title

Post de tranformare monofazat PTA 25/0.230kV. Schema electrica
PTA 25/0.230kV Single transformer post. Electrical diagram
Container CED

Scara / *Scale*

Codificare / Codification System

C	O	B	U	S	F	L	E	A	D	P	A	0	0	0	1	0	0	4	R	0	0

Istoricul reviziilor / Revision History

Rev.	Data/Date	Descriere Modificare / Modification description
1		
2		
3		
4		