


LEGEND:

PC1	-Solder 230V/AC
Q1	-Separable Circuit Breaker with Sensitivity RCD 500 mA
Q1-FCI	-Circuit Breaker with sensitivity RCD 30mA
Q1-H, CR1	-CR1
Q1-CMO	-Circuit Breaker with sensitivity RCD 300mA
Q1 to Q11	
KXO	-Power Contactor 300A...Type AC1
KC, KQ & KX1	-Relays 230V/AC
XBP-XA1 TO XA11	-Terminals block AC



D					
C					
B					
A					
Index	Data	Modificare	Proiectant	Approbat Consultant	Approbat CFR
		Modificator/Revisor	Designer	Approved Consultant	Approved CFR

**GUVERNUL ROMANIEI**
**PROIECT FINANȚAT DE UNIUNEA EUROPEANĂ**  
**ROMÂNIAN GOVERNMENT**
**EUROPEAN UNION FINANCED PROJECT**

CLIENT / CLIENT

**C.N.C.F. "C.F.R." - S.A.**

CONSULTANT / CONSULTANT

Approbat	Șef proiect	R. Lutzza	Data	11.2011	Semnatura
Approbat	Proiectant				
Approbat	Coordonator Secțiune 1	C. Gambailli	11.2011		<i>Cyrene</i>
Verificat	Section 1 Coordinator				
Checked	Expert Verifier	G. Buffarini	11.2011		<i>Buffarini</i>
	Checking Expert				

SUBCONTRACTANT / SUBCONTRACTOR

Approbat	Responsabil Subcontractant	A. Stancu - Dinulescu	11.2011		<i>Stancu</i>
Approbat	Subcontractor responsible				
Executat	Proiectant	M. Priporeanu	11.2011		<i>Priporeanu</i>

**AmX CONSULTING ENGINEERS**  
 Redabilitea liniei de cablu ferata Brasov - Sibieria, parte componenta a conditiilor IV Pan European, pentru circuliile trenurilor cu viteza maxima de 160 km/h.  
 Reabilitation of the railway Section 1 of the IV-Pan-European Corridor, for the trains operation with maximum speed of 160 km/h.  
 Section : Brasov - Sibiu/soara  
 Project/Project  
 2004/RO/16/PA/2003  
 Faza / Phase:  
 P.Th. / T.D.

Denumire desen / Drawing Title :

**STATIJA c.f. VANATORI/VANATORI RAILWAY STATION**  
**SCHEMA ELECTRICA A DULAPULUI TDx-cap X**  
**ELECTRICAL DIAGRAM FROM TDx PANEL-end X**

Codificare / Codification System

E	A	5	1	0	1	E	1	7	D	X	E	G	0	0	2	5	0	0	7	1
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

Scara / Scale: \_\_\_\_\_  
 LOT / LOT: \_\_\_\_\_  
 Nr. / No: 02 / 02

(297X630)