



NOTA / NOTE:

- Tabloul TAAR, se va livra cu grupul electrogen. / The TAAR board will be delivered together with the power unit.
- Comanda ventilatorului se va face din tabloul T.A.A.R. (permise in acelasi timp cu grupul electrogen). / The fan will be controlled from the TAAR board (starts at the same time as the power unit).

- LEGENDA / LEGEND:**
- Contactor electromagnetic tripol 16A, 400V, 50Hz. / Three-pole electromagnetic contactor 16A, 400V, 50Hz.
 - Ventilator grup electrogen 1.5kW, n=1600rot/min, 230/400V, IP54. / Fan generator 1.5kW, n=1600rot/min, 230/400V, IP54.
 - Cutie cu butoane / Box of buttons
 - Nisa / Niche
 - Tabloul electric / Electric board
 - Dulap prevazut in proiectul E.A.P. / Cabinet stipulated in the project E.A.P.
 - Dulap prevazut in proiectul E.A.P. / Cabinet stipulated in the project E.A.P.

Index	Data	Modificarea	Proiectant	Proiectant	Proiectant
Index	Date	Modification/Revision	Designer	Approved Consultant	Approved CFR
D					
C					
B					
A					



CLIENT / CLIENT

GUVERNUL ROMANIEI / ROMANIAN GOVERNMENT

PROIECT FINANȚAT DE UNIUNEA EUROPEANĂ / EUROPEAN UNION FINANCED PROJECT

C.N.C.F. "C.F.R." - S.A.



CONSULTANT / CONSULTANT

Approbat / Approved	Self project / Project manager	R. Liuzza	Data / Date	Semnatura / Signature
Approbat / Approved	Project manager	R. Liuzza	12.2011	
Approbat / Approved	Coordinator Section 1	C. Gambelli	12.2011	
Verificat / Checked	Expert Verifier	G. Fioravanti	12.2011	

SUBCONTRACTANT / SUBCONTRACTOR

Approbat / Approved	Responsabil Subcontractant / Subcontractant Responsible	A.Stanciu - Dinulescu	Data / Date	Semnatura / Signature
Approbat / Approved	Subcontractant Responsible	A.Stanciu - Dinulescu	12.2011	
Intocmit / Elaborated	Project Designer	D. Matei	12.2011	

Reabilitarea liniei de cale ferata Brasov - Simeria, parte componentă a coridorului IV Pan European, pentru circulația trenurilor cu viteză maximă de 160 km/h, Tronsoanel: Braşov - Sighişoara

Rehabilitation of the railway line Braşov - Simeria, component Part of the IV Pan-European Corridor, for the trains circulation with maximum speed of 160 km/h, Section: Braşov - Sighişoara

Proiect/Project 2004/RO/16/PPA/003

Faza / Phase: P.Th. / T.D.

Denumire desen / Drawing Title:

Recorduri electrice interioare de stație - Stația Boș /
Indoor electric connections station building

Codificare / Codification System	Scara / Scale	LOT / LOT	Nr. / No
E A 5 1 0 1 C 0 5 P A I E 0 0 2 1 0 2 2 1	1:50		01 / 01