



Alimentare Statie pompe / Supply of Pump station
 Alimentare Separator de uleiuri si hidrocarburi
 Supply of Oil and hydrocarbon separator

LEGENDA / LEGEND:

- Corp de iluminat cu balast electronic HF-P si gratar, echipat cu lampi tubulare fluorescente 2x36W, 230V, 50Hz, clase I, IP20
 Lighting unit with electronic ballast HF-P and grill, equipped with fluorescent tubular lamps 2x36W, 230V, 50Hz, class I, IP20
- Corp de iluminat cu balast electronic HF-P, echipat cu lampi tubulare fluorescente 2x36W, 230V, 50Hz, clase I, IP65
 Lighting unit with electronic ballast HF-P, equipped with fluorescent tubular lamps 2x36W, 230V, 50Hz, class I, IP65
- Corp de iluminat tip aplic, echipat cu lampa incandescenta 60W, 230V, 50Hz, clase I, IP54
 Lighting unit type aplic, equipped with incandescent lamp 60W, 230V, 50Hz, class I, IP54
- Corp de iluminat pentru mediu exploziv, echipat cu lampa incandescenta 100W, 230V, 50Hz, clase I, IP54
 Lighting unit for explosion-proof, equipped with incandescent lamp 100W, 230V, 50Hz, class I, IP54
- Corp de iluminat tip luminobloc 2x8W, iluminat permanent, cu autonomie de trei ore, 230V, 50Hz, clase II, IP42
 Lighting unit type luminobloc 2x8W, permanent lighting, three-hour autonomy, 230V, 50Hz, class II, IP42
- Comutator unipolar 250V, 10A
 Single change-over 250V, 10A
- Comutator unipolar etans 250V, 10A
 Single tight change-over 250V, 10A
- Intreruator unipolar 250V, 10A
 Single switch 250V, 10A
- Intreruator unipolar etans 250V, 10A
 Single tight switch 250V, 10A
- Priza bipolara, cu contact de protectie 250V/16A
 Two-poles socket outlet, with protection contact 250V /16A
- Priza tripolara cu contact de protectie si intreruator 400V/16A
 Three-poles socket outlet with protection contact and switch 400V /16A
- Priza bipolara etansa, cu contact de protectie 250V/16A
 Two-poles tight socket outlet, with protection contact 250V /16A
- Priza bipolara pentru radiator electric, cu contact de protectie 250V/16A
 Two-poles socket outlet for electric radiator, with protection contact 250V/16A
- Unitate exterioara de climatizare sistem monospilt 230V, 50Hz, P= 2KW
 Outdoor unit air conditioning system monospilt 230V, 50Hz, P= 2KW
- Unitate exterioara de climatizare sistem monospilt 230V, 50Hz, P= 3KW
 Outdoor unit air conditioning system monospilt 230V, 50Hz, P= 3KW
- Panou electric servicii auxiliare c.a.
 Electrical Panel for AC auxiliary services
- Tablou electric / Electric board

D					
C					
B					
A					
Indice	Data	Modificari	Proiectant	Aprobat Consultant	Aprobat CFR
		Modification/Revision	Designer	Approved Consultant	Approved CFR

GUVERNUL ROMANIEI ROMANIAN GOVERNMENT
PROIECT FINANȚAT DE UNIUNEA EUROPEANĂ EUROPEAN UNION FINANCED PROJECT

C.N.C.F. "C.F.R." - S.A.
CLIENT / CLIENT

ITALFERR GRUPPO FERROVIE DELLO STATO Joint Venture leader
Scott Wilson
OBERMEYER PLANEN + BERATEN GmbH
TECNIC Consulting Engineers

CONSULTANT / CONSULTANT				Data	Semnatura
				Date	Signature
Aprobat	Sef proiect		R. Liuzza	12.2011	
Aprobat	Coordonator Sectiune 1		C. Gambelli	12.2011	
Verificat	Expert Verificator		G. Fioravanti	12.2011	
Checked	Checking Expert				

SUBCONTRACTANT / SUBCONTRACTOR					
Aprobat	Responsabil Subcontractant		A.Stanciu - Dinulescu	12.2011	
Elaborat	Proiectant		D. Matei	12.2011	

Reabilitarea liniei de cale ferata Braşov - Simeria, parte componentă a coridorului IV Pan European, pentru circulația trenurilor cu viteză maximă de 160 km/h,
Tronsonul : Braşov - Sighişoara
 Rehabilitation of the railway line Braşov - Simeria, component Part of the IV Pan-European Corridor, for the trains circulation with maximum speed of 160 km/h,
Section : Braşov - Sighişoara

Denumire desen / Drawing Title :

Instalații electrice interioare bloc comandă - S.T. Măieruş;
Măieruş T.S.- Indoor wirings command building

Codificare / Codification System	Scara / Scale 1:50	LOT / LOT	Nr. / No 01 / 01
----------------------------------	--------------------	-----------	------------------

E A 5 1 0 1 C 0 8 P B I E 0 0 1 2 0 2 0 2