



NOTA / NOTE:

- Tabloul TAAR, se va livra cu grupul electrogen.
The TAAR board will be delivered together with the power unit.
- Comanda ventilatorului se va face din tabloul TAAR, (pompele in același timp cu grupul electrogen).
The fan will be controlled from the TAAR board, (starts at the same time as the power unit).

LEGENDA / LEGEND:

- Contactor electromagnetic tripolar 16A, 400V, 50Hz
Three-pole electromagnetic contactor 16A, 400V, 50Hz
- Ventilator grup electrogen 1.5kW, n=1500rot/min, 230/400V, IP54
Fan generator 1.5kW, n=1500rot/min, 230/400V, IP54
- Cutie cu butoane / Box of buttons
- F1, F2 - Niche / Niche
- Tabloul electric / Electric board
- Buton de pornire electropompa pentru stingerea incendiului montat in cutie capsulata pozitionata langa dulapul P.S.I.
Button for extinguishing the electric power installed in sealed box placed near the closest P.S.I.
- Dulap prevazut in proiectul E.A.P.
Closet stipulated in the project E.A.P.
- Dulap prevazut in proiectul E.A.P.
Closet stipulated in the project E.A.P.

Indice	Data	Modificari/Revision	Proiectant	Proiectant	Proiectant
D					
C					
B					
A					



GUVERNUL ROMANIEI / ROMANIAN GOVERNMENT
PROIECT FINANȚAT DE UNIUNEA EUROPEANĂ / EUROPEAN UNION FINANCED PROJECT
C.N.C.F. "C.F.R." - S.A.

CLIENT / CLIENT
ITALFERR GRUPPO FERROVIE DELLO STATO / Joint Venture leader
Scott Wilson
OBERMEYER PLANEN + BERATEN GmbH
TECNIC Consulting Engineers

CONSULTANT / CONSULTANT		Data	Semnătură / Signature
Approbat / Approved	Șef proiect / Project manager	12.2011	
Approbat / Approved	Coordonator Secțiune 1 / Section 1 Coordinator	12.2011	
Verificat / Checked	Expert Verificator / Checking Expert	12.2011	

SUBCONTRACTANT / SUBCONTRACTOR		Data	Semnătură / Signature
Approbat / Approved	Responsabil Subcontractant / Subcontractant Responsible	12.2011	
Elaborat / Elaborated	Proiectant / Designer	12.2011	

Reabilitarea liniei de cale ferata Braşov - Simeria, parte componentă a coridorului IV Pan European, pentru circulația trenurilor cu viteză maximă de 160 km/h,
Tronsoanel: Braşov - Sighişoara
Rehabilitation of the railway line Braşov - Simeria, component Part of the IV Pan-European Corridor, for the trains circulation with maximum speed of 160 km/h,
Section : Braşov - Sighişoara

Denumire desen / Drawing Title :

**Recorduri electrice interioare de la stație - Stația Apate;
Apate station - indoor electric connections station building**

Codificare / Codification System	Scara / Scale	LOT / LOT	Nr. / No
E A 5 1 0 1 C 0 9 P A I E 0 0 4 1 0 2 3 1	1:50		01 / 01