


- LEGENDA/ LEGEND :**
- conducta apa rece/ cold water pipe;
 - conducta apa calda/ hot water pipe;
 - conducta canalizare apa uzata menajera/ wastewater sewage pipe;
 - conducta din cupru la si de la panouri solare/ copper pipe to and from the solar panels;
- FS fonta de scurgere/ cast iron drain;
 RDS robinet dublu servici/ double service tap;
 M coloana apa uzata menajera/ wastewater column ;
 SP tifon de pardoseala/ floor trap;
 PC piesa de curatare/ cleaning piece;
 Red 100/75 reductie de la diametrul $\Phi 100$ la $\Phi 75$ / reduction from the diameter $\Phi 100$ to $\Phi 75$;
 B boiler trivalent (o serpentina de la panouri solare, o serpentina de la centrala termica si o rezistenta electrica)/ trivalent water heater (a coil from the solar panel, a coil from the thermal plant and an electrical resistance), $V=300l$, $P=9$ kW, $\Phi \times H = 0,58 \times 1,57$ m;
 CR clapeta de retinere (de sens unic)/ check valve (one-way sense);
 Rp recipient de pardoseala/ container floor, $0,8 \times 0,8 \times 0,8$ m;
 P + H grup pompare cu membrana si hidrofor/ pumping group with membrane and water pump, $q=1,16$ l/s, $H=20$ mCA, $P=0,94$ kW;
 RT rezervor tampon deschis/ open buffer, $V=0,75$ mc, $L \times l \times H = 0,7 \times 0,7 \times 1,84$ m;
 S sorb/ whirlpool;
 Cr cota radii/ foundation mark;
 DF dep de fonta/ iron cap.

D					
C					
B					
A					
Indice	Data	Modificari	Proiectant	Approbat	Approbat CFR
Index	Date	Modifications/Revisions	Designer	Approved Consultant	Approved CFR



CLIENT / CLIENT
 C.N.C.F. "C.F.R." - S.A.



CONSULTANT / CONSULTANT		Data	Semnatura
Approbat	Responsabil Proiect	DEC. 2011	[Signature]
Verificat	Coordonator Sectiune 1	DEC. 2011	[Signature]
Checkat	Expert Cheie / Key Expert	DEC. 2011	[Signature]

SUBCONTRACTANT / SUBCONTRACTOR		Data	Semnatura
Approbat	Responsabil Subcontractant	DEC. 2011	[Signature]
Verificat	Proiectant	DEC. 2011	[Signature]

Reabilitarea liniei de cale ferata Bragov - Simeria, parte componenta a coridorului IV Pan European, pentru circulatia trenurilor cu viteza maxima de 160 km/h, Tronsoanel: Bragov - Sighisoara
 Rehabilitation of the railway line Bragov - Simeria, component Part of the IV Pan-European Corridor, for the train circulation with maximum speed of 160 km/h, Section : Bragov - Sighisoara

Denumire desen / Drawing Title :
 STATIA C.F. VANATORI / RAILWAY STATION VANATORI/
 CLADIREA STATIEI / STATION BUILDING
 Schema coloanelor - Instalati sanitare Interioare, statie hidrofor
 Indoor sanitary Installations - Columns scheme, pumping station

Codificare / Codification System	Scara / Scale	LOT / LOT	Nr. / No
E A 5 1 0 1 E 1 7 D B 1 8 0 0 8 1 0 3 5 1	1:50		01/01

A2 (420x1337) = 0.56m